

Dichiarazione di conformita'
Declaration of Conformity

La Societa':
The Company:

SCHNEIDER ELECTRIC INDUSTRIE ITALIA S.p.A.

Stabilimento
Factory

Via Circonvallazione Est, 1
24040 Stezzano (BG)
ITALY

Sede Legale
Head Office

Via Circonvallazione Est, 1
24040 Stezzano (BG)
ITALY

dichiara sotto la propria responsabilita' che il prodotto/i:
state on our own responsibility that the product/s:

CENTRALINI MODULARI IP65 SERIE KAEDRA
WALL MOUNTING DISTRIBUTION BOARD IP 65 KAEDRA SERIES

è/sono conforme/i ai seguenti documenti:
is/are in conformity with the following documents:

- **IEC 60670-1**

Resistenza U.V.

Gli involucri sono stati sottoposti alla prova : "Xenon 1200 (ISO 4892/2)65°C/60W/m²/300/400 nm"
che ha dato i seguenti risultati:

INDICE DI INGIALLIMENTO : 3,5 dopo 500h e 5 dopo 2000h di esposizione

RESISTENZA ALL'IMPATTO a 23°C : 20J dopo 500h e 12J dopo 2000h di esposizione

U.V. resistance


The enclosures are submitted to test : "Xenon 1200 (ISO 4892/2)65°C/60W/m²/300/400 nm" and the test result are :

YELLOW INDEX : 3,5 after 500h and 5 after 2000h to exposure

IMPACT RESISTENCE 23°C : 20J after 500h and 12J after 2000h to exposure

Stezzano 30/03/2016

Martino Amodeo
Plant Manager
Industry-Enclosures and
mounting & cabling accessories



Signature / STAMP