

Form F601/01 – Certificate of Compliance

F601/01

Certificate of Compliance

Code of Practice One Issue 2
Code of Practice Two Issue 4
Code of Practice Three Issue 5

Application Reference No: P-C/1-1/2-3/031/05

Issued To: Schneider Electric, 2195 Keating Cross Road, Saanichton, British Columbia V8M 2A5 Canada

Meter Description: Meter with integral Outstation Type: ION7650 and 7550 Firmware Version: V356

Test Reference No. EMA109817 Issue 4 & 5 Date of Test: 13/08/09 Software Version: N/A

Test Laboratory: SGS UK Ltd, Unit 10, Bowburn South Ind. Estate, DH6 5AD, Durham, United Kingdom


Test Environment:

Schneider Electric's Metering Equipment has undergone Compliance Testing in accordance with Code of Practice One Issue 2 (v3.0) and Code of Practice Two Issue 4 (v3.0) and a review of the test results against the requirements of Code of Practice Three Issue 5.

The Metering Equipment was tested in conjunction with the Manufacturer's "ION Setup version 2.1".

Certificate of Compliance:

The review of the Compliance Testing results on 30th September 2009 and subsequent firmware revisions confirmed that the Metering Equipment was found to comply with the requirements of Code of Practice One Issue 2, Code of Practice Two Issue 4 and Code of Practice 3 Issue 5.

Signed:  Date:15th December 2009.....
On Behalf of the Panel, ELEXON Limited (as the Balancing and Settlement Code Company ('BSCCo'))

Form F601/01 – Certificate of Compliance

F601/01

Certificate of Compliance**Code of Practice One Issue 2
Code of Practice Two Issue 4
Code of Practice Three Issue 5**

Application Reference No: P-C/1-1/2-3/031/05

Issued To: Schneider Electric, 2195 Keating Cross Road, Saanichton, British Columbia V8M 2A5 Canada

Meter Description: N/A

Type: ION8800

Firmware Version: REV 8800 V335

Test Reference No. EMA109817 Issue 4 & 5

Date of Test: 13/08/09

Software Version: N/A

Test Laboratory: SGS UK Ltd, Unit 10, Bowburn South Ind. Estate, DH6 5AD, Durham, United Kingdom

Test Environment:

Schneider Electric's Metering Equipment has undergone Compliance Testing in accordance with Code of Practice One Issue 2 (v3.0) and Code of Practice Two Issue 4 (v3.0) and a review of the test results against the requirements of Code of Practice Three Issue 5.

The Metering Equipment was tested in conjunction with the Manufacturer's "ION Setup version 2.1".

Certificate of Compliance:

The review of the Compliance Testing results on 30th September 2009 and subsequent firmware revisions confirmed that the Metering Equipment was found to comply with the requirements of Code of Practice One Issue 2, Code of Practice Two Issue 4 and Code of Practice 3 Issue 5.

Signed:

Date:15th December 2009.....

On Behalf of the Panel, ELEXON Limited (as the Balancing and Settlement Code Company ('BSCCo'))