

Certificate of Compliance

Certificate Number 20040914-E215117
Report Reference E215117, June 7, 2001
Issue Date 2004 September 14

Page 1 of 2



**Underwriters
Laboratories Inc.**

Issued to:

SCHNEIDER ELECTRIC INDUSTRIES S A

Av Des Jeux Olympiques
38505 Grenoble Cedex 9, France

*This is to certify that
representative samples of*

Branch Circuit Breakers
Type C60 or C60N

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

**UL 489 Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-
Breaker Enclosures**

Additional Information:

See Addendum for Ratings Information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Susan Amir*
Susan Amir, Project Handler II
Underwriters Laboratories Inc.

Reviewed by: *Antonio Romanacce*
Antonio Romanacce, Sr. Project Engineer
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 20040914-E215117
Report Reference E215117, June 7, 2001
Issue Date 2004 September 14

Page 2 of 2



**Underwriters
Laboratories Inc.**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Electrical Ratings:

<u>Construction</u>	<u>V</u>	<u>Ampere Ratings</u>	<u>Interrupting Rating</u>
1P	120 ac	0.5 through 35 A	10,000 A
1P	240 ac	0.5 through 35 A	5,000 A
2P & 3P	240 ac	0.5 through 35 A	10,000 A
1P	60 dc	0.5 through 63 A	10,000 A
1P (2P Series)	125 dc	0.5 through 35 A	10,000 A

Issued by: *Susan Amir*
Susan Amir, Project Handler II
Underwriters Laboratories Inc.

Reviewed by: *Antonio Romanacce*
Antonio Romanacce, Sr. Project Engineer
Underwriters Laboratories Inc.