

# Easy-UPS Online SNMP Card (APV9601) Firmware Upgrade


# Easy-UPS Online SNMP Card (APV9601) Firmware Upgrade

**Step 1:** Turn off your computer's firewall. (optional)

Your computer's firewall may block the update feature. If the update fails, be sure to turn off the firewall.

**Step 2:** Open SNMP Manager


On the Taskbar, click on the arrow up to show hidden icons. Right click on the SchneiderUPS icon and click SNMP Manager.



# Easy-UPS Online SNMP Card (APV9601) Firmware Upgrade

**Step 3:** Select the FTP server IP address.


**NOTE:** If applying upgrade for SNMP Web Server in LAN, FTP server IP address will be IP address of current PC in LAN. If applying upgrade for SNMP Web Server in specific networking, FTP server IP address will be IP address of current PC in Internet.



# Easy-UPS Online SNMP Card (APV9601) Firmware Upgrade

Step 4: Click “Browse” button to choose program file.

**NOTE:** Program file will be named \*.s19




# Easy-UPS Online SNMP Card (APV9601) Firmware Upgrade

## Step 5: Select devices to upgrade.

Select the radio button from one of the following:


- Upgrade the selected device
- Upgrade all un-upgraded devices
- Force to upgrade all devices



# Easy-UPS Online SNMP Card (APV9601) Firmware Upgrade

**Step 6:** Click “Upgrade” button to execute upgrade action.

**NOTE:** If prompted for password, enter the password and click “Apply”. Default password is 12345678.



# Easy-UPS Online SNMP Card (APV9601) Firmware Upgrade

Step 7: Check the output window to see if the upgrade was successful.

The screenshot shows the 'SNMP Web Manager' interface. The 'Online upgrade' tab is active, displaying a progress bar at 100%. The output window shows the following log entries:

```
[14:43:31] 192.168.103.60 Online successfully.  
[14:45:20] 192.168.103.60 Ready to upgrade for the 1 time.  
[14:45:27] 192.168.103.60 Start formatting.  
[14:45:32] 192.168.103.60 Formatting is completed.  
[14:45:32] 192.168.103.60 Upgrading files. Please wait.  
[14:45:42] 192.168.103.60 Upgrade is completed.
```

The last line of the log is highlighted with a red box.

Life Is On



**Schneider**  
Electric

