



# Certificate of Compliance

**Certificate:** 1156184

**Master Contract:** 240515

**Project:** 70110012

**Date Issued:** 2017-03-09

**Issued to:** Telemecanique/Schneider Electric Industries SAS  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
FRANCE  
Attention: Christophe Delaitre

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Khalil Ouldchama*  
Khalil Ouldchama, P. Eng.

## **PRODUCTS**

CLASS - C321103 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Auxiliary Devices

Limit switches, rated A300-Q300, Models XCS-A, XCS-B, XCS-C and XCS-E, followed by three to seven digit number, Type 4, 4X and 12 enclosure.

Limit switch, Model XCS-E1715564, rated 24V ac/dc, 4A ac, 0.55A dc, Type 4, 4X and 12 enclosure.

## **APPLICABLE REQUIREMENTS**

CSA-C22.2 No. 14-13 - Industrial Control Equipment  
CSA-C22.2 No. 94-M91 - Special Purpose Enclosures



## *Supplement to Certificate of Compliance*

**Certificate:** 1156184

**Master Contract:** 240515 (240515)

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>
70110012	2017-03-09	Update to Report 1156184, to cover addition of alternate (accepted) plastic material, alternate magnet wire and accepted alternate insulating tape. As per CSA-C22.2 No.14-13. <b>Master Contract number 225619 is changed to 240515 on September 21, 2007.</b>
1663720	2005-04-20	Addition of limit switch, Model XCS-E1715564 and alternate cover. <b>Master Contract number 164581 is changed to 225619.</b>
<b>History</b>		
1433316	2003-04-29	Addition of 2NC contacts actuated by the electromagnet.
1156184	2001-01-02	Addition of Models XCS-A1656148 and XCS-B1618829. <b>Report 164581-1156184 supersedes report LR 44087-115.</b>
LR 44087-141	1999-03-03	Addition of Model XCS-B.
LR 44087-128	1998-02-25	Addition of Model XCS-E.
LR 44087-115	1997-12-15	Limit switches, Models XCS-A and XCS-C. <b>Report LR 44087-115 is superseded by report 164581-1156184.</b>