



Product Service

CERTIFICATE

No. Z10 057630 0015 Rev. 00

Holder of Certificate: **Schneider Electric Industries SAS**

BP660 Zone Industrielle
16340 L'isle d' Espagnac
FRANCE

Certification Mark:



Product: **Safety components**

Safety interface (Type 4)

Model(s): **XPSLCMUT1160**

Parameters:

Power Supply:	24 Vdc \pm 20%
Power Consumption:	5 W
Output Relays:	Max. voltage 250Vac; max. current 2A
Operating Temperature:	0 °C to +55 °C
IP Code :	IP20

Tested according to:

2006/42/EC
EN 61496-1:2013 (Type 4)
EN 62061:2005/A2:2015 (SIL CL3)
EN ISO 13849-1:2015 (Cat 4, PL e)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: SL96858T
Valid until: 2025-11-19

Date, 2021-05-20

(Peter Weiß)